



Herbicides in Drinking Water
Analysis Report

Address: 1100 W 49th St
Austin, TX 78756
Mail: PO Box 149347, MC-1947
Austin, TX 78714-9347
envsciadmin@dshs.texas.gov
www.dshs.state.tx.us
512-776-7587

Texas Department of State
Health Services

Submitter ID # (PWS ID #): 1870034

CANYON PARK WSC
SIMARD, ROBERT
PO BOX 1928
ONALASKA, TX 77360-1928



Date Reported : 09/12/2024
Report ID# : 20240912095835AG96195

Lab Sample ID# : AG96195 Water Source :
Sample Priority : NORMAL Entry Point(s) : EP001
TCEQ Sample ID: 2421942

Date Collected : 08/20/2024 10:08 Conc. Units : µg/L
Date Received : 08/21/2024 Method : 515.4 Rev. 1.0
Date Analyzed : 08/29/2024 Analyst : RM
Extraction Date : 08/26/2024 Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier
2,4-D ¹	<0.1	
2,4,5-TP (Silvex) ¹	<0.2	
Pentachlorophenol ¹	<0.04	
Dalapon ¹	<1	
Dinoseb ¹	<0.2	
Picloram ¹	<0.1	
Non Regulated Compounds	Result	Qualifier
Acifluorfen	<1.0	
Bentazon	<2.0	
Chloramben	<1.0	
2,4-DB	<2.0	
Dicamba	<1.0	
3,5-Dichlorobenzoic acid	<1.0	
Dichlorprop	<2.0	
Quinclorac	<1.0	
2,4,5-T	<0.5	

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(¹) meet all TNI (2016 Standard) requirements.

Authorized by Chemist IV BFLAMMANG on 09/11/2024