



Pesticides by Method 508.1
Analysis Report

Address: 1100 W 49th St
Austin, TX 78756
Mail: PO Box 149347, MC-1947
Austin, TX 78714-9347
envsciadmin@dshs.texas.gov
www.dshs.state.tx.us
512-776-7587

Texas Department of State
Health Services

Submitter ID # (PWS ID #): 1870034

CANYON PARK WSC
SIMARD, ROBERT
PO BOX 1928
ONALASKA, TX 77360-1928

Date Reported : 10/30/2025
Report ID# : 20251030082210AH39260

Lab Sample ID# : AH39260 Water Source :
Sample Priority : NORMAL Entry Point(s) : EP001
TCEQ Sample ID: 2508275

Date Collected : 09/02/2025 10:02 Conc. Units : ug/L
Date Received : 09/03/2025 Method : 508.1 Rev. 2.0
Date Analyzed : 09/16/2025 Analyst : TS
Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier
Chlordane ¹	<0.2	
Endrin ¹	<0.01	
Heptachlor epoxide ¹	<0.02	
Toxaphene ¹	<1.	
Screened Compounds	Result	Qualifier
Aroclor 1016 ²	<0.08	
Aroclor 1221 ²	<20.	
Aroclor 1232 ²	<0.5	
Aroclor 1242 ²	<0.3	
Aroclor 1248 ²	<0.1	
Aroclor 1254 ²	<0.1	
Aroclor 1260 ²	<0.2	

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(¹) meet all TNI (2016 Standard) requirements. The test results for analytes noted(²) meet all TNI (2016 Standard) requirements for Aroclor Identification. Aroclor quantitation is not accredited.

Authorized by Team Lead JHE on 10/29/2025



**Texas Department of State
Health Services**

**Semivolatiles Organic
Analysis Report**

Address: 1100 W 49th St
Austin, TX 78756
Mail: PO Box 149347, MC-1947
Austin, TX 78714-9347
envsciadmin@dshs.texas.gov
www.dshs.state.tx.us
512-776-7587

Submitter ID # (PWS ID #): 1870034

CANYON PARK WSC
SIMARD, ROBERT
PO BOX 1928
ONALASKA, TX 77360-1928

Date Reported : 10/30/2025
Report ID# : 20251030082210AH39260

Lab Sample ID# : AH39260 Water Source :
Sample Priority : NORMAL Entry Point(s) : EP001
TCEQ Sample ID: 2508275

Date Collected : 09/02/2025 10:02 Conc. Units : µg/L
Date Received : 09/03/2025 Method : EPA 525.2
Date Analyzed : 09/18/2025 Analyst : RR
Extraction Date : 09/05/2025 Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier	Monitored Compounds continued	Result	Qualifier
Alachlor ¹	<0.2		Dimethylphthalate	<2.1	
Atrazine ¹	<0.1		Fluorene	<0.21	
Benzo[a]pyrene ¹	<0.02		2,2',3,3',4,4',6-Heptachlorobiphenyl	<0.51	
alpha-Chlordane	<0.2		2,2',4,4',5,6'-Hexachlorobiphenyl	<0.21	
gamma-Chlordane	<0.2		Indeno[1,2,3-cd]pyrene	<0.21	
trans-Nonachlor	<0.2		Metolachlor	<0.21	
Di(2-ethylhexyl) adipate ¹	<0.6		Metribuzin	<0.21	
Di(2-ethylhexyl) phthalate ¹	<0.6		Naphthalene	<0.21	
Heptachlor ¹	<0.04		2,2',3,3',4,5',6,6'-Octachlorobiphenyl	<0.51	
Hexachlorobenzene ¹	<0.1		2,2',3',4,6-Pentachlorobiphenyl	<0.21	
Hexachlorocyclopentadiene ¹	<0.1	*	Phenanthrene	<0.21	
Lindane ¹	<0.02		Propachlor	<0.21	
Methoxychlor ¹	<0.1		Pyrene	<0.21	
Simazine ¹	<0.07		2,2',4,4'-Tetrachlorobiphenyl	<0.21	
			2,4,5-Trichlorobiphenyl	<0.21	
Monitored Compounds	Result	Qualifier	Trifluralin	<0.21	
Acenaphthene	<0.21		Comments:		
Acenaphthylene	<0.21		* - This analyte has known instability and/or method		
Aldrin	<0.21	*	performance issues and quantitation should be considered		
Anthracene	<0.21		approximate.		
Benzo(a)anthracene	<0.21		The test results on this report relate only to the sample		
Benzo[b]fluoranthene	<0.21		identified on this report. The test results for analytes noted(')		
Benzo[g,h,i]perylene	<0.21		meet all TNI (2016 Standard) requirements.		
Benzo[k]fluoranthene	<0.21		Authorized by Team Lead JHE on 10/29/2025		
Bromacil	<0.21				
Butachlor	<0.21				
Butylbenzylphthalate	<2.1				
2-Chlorobiphenyl	<0.21				
Chrysene	<0.21				
Dibenz[a,h]anthracene	<0.21				
Di-n-butylphthalate	<2.1				
2,3-Dichlorobiphenyl	<0.21				
Dieldrin	<0.21				
Diethylphthalate	<2.1				